



EQUIPMENT TYPE APPROVAL

Distribution Customer Use

We hereby confirm that below detailed Equipment is in compliance with the latest relevant regulations and standards, therefore it is **Approved** to be used in Distribution Customer Installation for five years from issuance date, where expiry date is due the Approval Holder shall apply for renewal if needed.

Approval Details	
Approval ID: <i>230130</i>	Approval Holder: <i>Unique Power Switchgears UPS W.L.L</i>
Approval Type: <i>Distribution Customer Use</i>	Valid Till: <i>01/23/2028</i>
Equipment Details	
Category: <i>LV Switchgears</i>	Trademark: <i>L & T</i>
Description: <i>Annexure-A</i>	Designation: <i>Annexure-A</i>
Manufacture Details	
Name: <i>L & T Electrical and Automation</i>	Country of Origin: <i>India</i>

Comments:

EDD Requirements Fulfilled

Signature:

Director, Electricity Distribution

Stamp:



To: unique@uniquepowerswitchgears.com

TERMS AND CONDITIONS

1. The Directorate reserves the right to deny or disconnect electricity supply in case of any failure to comply with any compulsory provision of the latest relevant regulations and standards enforced by the Kingdom.
2. The Directorate retains the right to publish a censored copy of the approval.
3. The Approval Holder shall observe and adhere to the latest relevant regulations and standards.
4. The Approval Holder shall observe and adhere to the latest EDD Equipment Approval guidelines and instructions which are made available on EDD Equipment Approval Web Page.
5. The Approval Holder shall ensure that an Equipment is in compliance with the latest relevant regulations and standards, and it shall not cause any harm that endangers the safety of persons, property, or environment.
6. The Approval Holder shall ensure that all provided information are accurate, relevant, correct, and complete, and that the documents submitted along with the application are true, genuine, and authentic.
7. The Approval Holder shall provide any required information, documents, and samples necessary to demonstrate Equipment conformity with the latest relevant regulations and standards.
8. The Approval Holder is responsible for retaining all relevant information and documents for five years from issuance date.
9. The Approval Holder is responsible to present the approval in full without any omissions upon request.
10. The Approval is applicable whenever an Equipment is meeting the following provisions:
 - A. Classified in Applicable Standards List as Distribution Customer Use Equipment.
 - B. Meant to be used in Distribution Customer Installation.
11. The Approval Holder for this approval shall be Supplier licensed by MOIC to place Equipment on local market.
12. The Approval Holder shall apply for the approval before placing any Equipment on local market.
13. The Approval Holder is responsible to ensure that the approved Equipment is manufactured, tested, delivered, and stored in accordance with the latest relevant regulation and standards.
14. The Installation Contractor is responsible to ensure that an approved Equipment is installed in accordance with the latest relevant regulation and standards.

ANNEXURE-A

Item No.	Item Description	Item Designation
1	16A 30mA 2P RCCB	XXXXXX
2	20A 30mA 2P RCCB	XXXXXX
3	25A 30mA 2P RCCB	XXXXXX
4	32A 30mA 2P RCCB	XXXXXX
5	40A 30mA 2P RCCB	XXXXXX
6	63A 30mA 2P RCCB	XXXXXX
7	100A 30mA 2P RCCB	XXXXXX
8	16A 30mA 4P RCCB	XXXXXX
9	20A 30mA 4P RCCB	XXXXXX
10	25A 30mA 4P RCCB	XXXXXX
11	32A 30mA 4P RCCB	XXXXXX
12	40A 30mA 4P RCCB	XXXXXX
13	63A 30mA 4P RCCB	XXXXXX
14	100A 30mA 4P RCCB	XXXXXX
15	16A 100mA 2P RCCB	XXXXXX
16	20A 100mA 2P RCCB	XXXXXX
17	25A 100mA 2P RCCB	XXXXXX
18	32A 100mA 2P RCCB	XXXXXX
19	40A 100mA 2P RCCB	XXXXXX
20	63A 100mA 2P RCCB	XXXXXX
21	100A 100mA 2P RCCB	XXXXXX
22	16A 100mA 4P RCCB	XXXXXX
23	20A 100mA 4P RCCB	XXXXXX
24	25A 100mA 4P RCCB	XXXXXX
25	32A 100mA 4P RCCB	XXXXXX
26	40A 100mA 4P RCCB	XXXXXX
27	63A 100mA 4P RCCB	XXXXXX
28	100A 100mA 4P RCCB	XXXXXX
29	16A 300mA 2P RCCB	XXXXXX
30	20A 300mA 2P RCCB	XXXXXX
31	25A 300mA 2P RCCB	XXXXXX
32	32A 300mA 2P RCCB	XXXXXX
33	40A 300mA 2P RCCB	XXXXXX
34	63A 300mA 2P RCCB	XXXXXX
35	100A 300mA 2P RCCB	XXXXXX
36	16A 300mA 4P RCCB	XXXXXX
37	20A 300mA 4P RCCB	XXXXXX
38	25A 300mA 4P RCCB	XXXXXX
39	32A 300mA 4P RCCB	XXXXXX
40	40A 300mA 4P RCCB	XXXXXX
41	63A 300mA 4P RCCB	XXXXXX
42	100A 300mA 4P RCCB	XXXXXX
43	16A 500mA 2P RCCB	XXXXXX

44	20A 500mA 2P RCCB	XXXXXX
45	25A 500mA 2P RCCB	XXXXXX
46	32A 500mA 2P RCCB	XXXXXX
47	40A 500mA 2P RCCB	XXXXXX
48	63A 500mA 2P RCCB	XXXXXX
49	100A 500mA 2P RCCB	XXXXXX
50	16A 500mA 4P RCCB	XXXXXX
51	20A 500mA 4P RCCB	XXXXXX
52	25A 500mA 4P RCCB	XXXXXX
53	32A 500mA 4P RCCB	XXXXXX
54	40A 500mA 4P RCCB	XXXXXX
55	63A 500mA 4P RCCB	XXXXXX
56	100A 500mA 4P RCCB	XXXXXX

