



EQUIPMENT TYPE APPROVAL

Distribution Customer Use

We hereby confirm that below detailed Equipment is in compliance with the latest relevant regulations and standards, therefore it is **Approved** to be used in Distribution Customer Installation for five years, where expiry date is due the Approval Holder shall apply for renewal if needed.

Approval Details	
Approval ID: <i>230584</i>	Approval Holder: <i>Voltamp Switchgear Co.</i>
Approval Type: <i>Distribution Customer Use</i>	Valid Till: <i>04/17/2028</i>
Equipment Details	
Category: <i>LV Switchgears</i>	Trademark: <i>Onesto</i>
Description: <i>Annexure-A</i>	Designation: <i>Annexure-A</i>
Manufacturer Details	
Name: <i>Wenzhou Aoelec Electrical Co. Ltd</i>	Country of Origin: <i>China</i>

Comments:

EDD Requirements Fulfilled

Signature:

04/19/2023 02:07 PM

Director, Electricity Distribution

Stamp:



To: voltamp@batelco.com.bh

TERMS AND CONDITIONS

1. The Directorate reserves the right to deny or disconnect electricity supply in case of any failure to comply with any compulsory provision of the latest relevant regulations and standards enforced by the Kingdom.
2. The Directorate retains the right to publish a censored copy of the approval.
3. The Approval Holder shall observe and adhere to the latest relevant regulations and standards.
4. The Approval Holder shall observe and adhere to the latest EDD Equipment Approval guidelines and instructions which are made available on EDD Equipment Approval Web Page.
5. The Approval Holder shall ensure that an Equipment is in compliance with the latest relevant regulations and standards, and it shall not cause any harm that endangers the safety of persons, property, or environment.
6. The Approval Holder shall ensure that all provided information are accurate, relevant, correct, and complete, and that the documents submitted along with the application are true, genuine, and authentic.
7. The Approval Holder shall provide any required information, documents, and samples necessary to demonstrate Equipment conformity with the latest relevant regulations and standards.
8. The Approval Holder is responsible for retaining all relevant information and documents for five years from issuance date.
9. The Approval Holder is responsible to present the approval in full without any omissions upon request.
10. The Approval is applicable whenever an Equipment is meeting the following provisions:
 - A. Classified in Applicable Standards List as Distribution Customer Use Equipment.
 - B. Meant to be used in Distribution Customer Installation.
11. The Approval Holder for this approval shall be Supplier licensed by MOIC to place Equipment on local market.
12. The Approval Holder shall apply for the approval before placing any Equipment on local market.
13. The Approval Holder is responsible to ensure that the approved Equipment is manufactured, tested, delivered, and stored in accordance with the latest relevant regulation and standards.
14. The Installation Contractor is responsible to ensure that an approved Equipment is installed in accordance with the latest relevant regulation and standards.

ANNEXURE-A

No.	Description	Designation
1	16A 3P 35kA MCCB	KCM1-100S-0163
2	20A 3P 35kA MCCB	KCM1-100S-0203
3	32A 3P 35kA MCCB	KCM1-100S-0323
4	40A 3P 35kA MCCB	KCM1-100S-0403
5	63A 3P 35kA MCCB	KCM1-100S-0633
6	80A 3P 35kA MCCB	KCM1-100S-0803
7	100A 3P 35kA MCCB	KCM1-100S-1003
8	16A 3P+N 35kA MCCB	KCM1-100S-0164
9	20A 3P+N 35kA MCCB	KCM1-100S-0204
10	32A 3P+N 35kA MCCB	KCM1-100S-0324
11	40A 3P+N 35kA MCCB	KCM1-100S-0404
12	63A 3P+N 35kA MCCB	KCM1-100S-0634
13	100A 3P+N 35kA MCCB	KCM1-100S-1004
14	100A 3P 50kA MCCB	KCM1-225S-1003
15	125A 3P 50kA MCCB	KCM1-225S-1253
16	160A 3P 50kA MCCB	KCM1-225S-1603
17	200A 3P 50kA MCCB	KCM1-225S-2003
18	225A 3P 50kA MCCB	KCM1-225S-2253
19	100A 3P+N 50kA MCCB	KCM1-225S-1004
20	125A 3P+N 50kA MCCB	KCM1-225S-1254
21	160A 3P+N 50kA MCCB	KCM1-225S-1604
22	200A 3P+N 50kA MCCB	KCM1-225S-2004
23	225A 3P+N 50kA MCCB	KCM1-225S-2254
24	250A 3P 50kA MCCB	KCM1-400S-2503
25	315A 3P 50kA MCCB	KCM1-400S-3153
26	400A 3P 50kA MCCB	KCM1-400S-4003
27	250A 3P+N 50kA MCCB	KCM1-400S-2504
28	315A 3P+N 50kA MCCB	KCM1-400S-3154
29	400A 3P+N 50kA MCCB	KCM1-400S-4004
30	500A 3P 50kA MCCB	KCM1-630S-5003
31	630A 3P 50kA MCCB	KCM1-630S-6303
32	500A 3P+N 50kA MCCB	KCM1-630S-5004
33	630A 3P+N 50kA MCCB	KCM1-630S-6304