



## EQUIPMENT TYPE APPROVAL

### Distribution Customer Use

We hereby confirm that below detailed Equipment is in compliance with the latest relevant regulations and standards, therefore it is **Approved** to be used in Distribution Customer Installation for five years, where expiry date is due the Approval Holder shall apply for renewal if needed.

Approval Details	
Approval ID: <i>230725</i>	Approval Holder: <i>Bahrain Switchgear &amp; Lighting Industries W.L.L.</i>
Approval Type: <i>Distribution Customer Use</i>	Valid Till: <i>05/21/2028</i>
Equipment Details	
Category: <i>LV Switchgears</i>	Trademark: <i>ABB</i>
Description: <i>Annexure-A</i>	Designation: <i>Annexure-A</i>
Manufacturer Details	
Name: <i>ABB S.p.A</i>	Country of Origin: <i>Italy</i>

#### Comments:

*EDD Requirements Fulfilled*

Signature:

05/23/2023 08:48 AM

Director, Electricity Distribution

Stamp:



To: [bsli@bahrainswitchgear.com](mailto:bsli@bahrainswitchgear.com)

## TERMS AND CONDITIONS

1. The Directorate reserves the right to deny or disconnect electricity supply in case of any failure to comply with any compulsory provision of the latest relevant regulations and standards enforced by the Kingdom.
2. The Directorate retains the right to publish a censored copy of the approval.
3. The Approval Holder shall observe and adhere to the latest relevant regulations and standards.
4. The Approval Holder shall observe and adhere to the latest EDD Equipment Approval guidelines and instructions which are made available on EDD Equipment Approval Web Page.
5. The Approval Holder shall ensure that an Equipment is in compliance with the latest relevant regulations and standards, and it shall not cause any harm that endangers the safety of persons, property, or environment.
6. The Approval Holder shall ensure that all provided information are accurate, relevant, correct, and complete, and that the documents submitted along with the application are true, genuine, and authentic.
7. The Approval Holder shall provide any required information, documents, and samples necessary to demonstrate Equipment conformity with the latest relevant regulations and standards.
8. The Approval Holder is responsible for retaining all relevant information and documents for five years from issuance date.
9. The Approval Holder is responsible to present the approval in full without any omissions upon request.
10. The Approval is applicable whenever an Equipment is meeting the following provisions:
  - A. Classified in Applicable Standards List as Distribution Customer Use Equipment.
  - B. Meant to be used in Distribution Customer Installation.
11. The Approval Holder for this approval shall be Supplier licensed by MOIC to place Equipment on local market.
12. The Approval Holder shall apply for the approval before placing any Equipment on local market.
13. The Approval Holder is responsible to ensure that the approved Equipment is manufactured, tested, delivered, and stored in accordance with the latest relevant regulation and standards.
14. The Installation Contractor is responsible to ensure that an approved Equipment is installed in accordance with the latest relevant regulation and standards.

**ANNEXURE-A**

<b>No.</b>	<b>Description</b>	<b>Designation</b>
1	6A 1P+N 10mA, 10KA RCBO	DSE201 M 2CSR275153R0065
2	10A 1P+N 10mA, 10KA RCBO	DSE201 M 2CSR275153R0105
3	16A 1P+N 10mA, 10KA RCBO	DSE201 M 2CSR275153R0165
4	20A 1P+N 10mA, 10KA RCBO	DSE201 M 2CSR275153R0205
5	25A 1P+N 10mA, 10KA RCBO	DSE201 M 2CSR275153R0255
6	32A 1P+N 10mA, 10KA RCBO	DSE201 M 2CSR275153R0325
7	40A 1P+N 10mA, 10KA RCBO	DSE201 M 2CSR275153R0405
8	50A 1P+N 10mA, 10KA RCBO	DSE201 M 2CSR275153R0505
9	6A 1P+N 30mA, 10KA RCBO	DSE201 M 2CSR275153R1065
10	10A 1P+N 30mA, 10KA RCBO	DSE201 M 2CSR275153R1105
11	16A 1P+N 30mA, 10KA RCBO	DSE201 M 2CSR275153R1165
12	20A 1P+N 30mA, 10KA RCBO	DSE201 M 2CSR275153R1205
13	25A 1P+N 30mA, 10KA RCBO	DSE201 M 2CSR275153R1255
14	32A 1P+N 30mA, 10KA RCBO	DSE201 M 2CSR275153R1325
15	40A 1P+N 30mA, 10KA RCBO	DSE201 M 2CSR275153R1405
16	50A 1P+N 30mA, 10KA RCBO	DSE201 M 2CSR275153R1505
17	6A 1P+N 100mA, 10KA RCBO	DSE201 M 2CSR275153R2064
18	10A 1P+N 100mA, 10KA RCBO	DSE201 M 2CSR275153R2104
19	16A 1P+N 100mA, 10KA RCBO	DSE201 M 2CSR275153R2164
20	20A 1P+N 100mA, 10KA RCBO	DSE201 M 2CSR275153R2204
21	25A 1P+N 100mA, 10KA RCBO	DSE201 M 2CSR275153R2254
22	32A 1P+N 100mA, 10KA RCBO	DSE201 M 2CSR275153R2324
23	40A 1P+N 100mA, 10KA RCBO	DSE201 M 2CSR275153R2404
24	50A 1P+N 100mA, 10KA RCBO	DSE201 M 2CSR275153R2504
25	6A 1P+N 300mA, 10KA RCBO	DSE201 M 2CSR375153R3064
26	10A 1P+N 300mA, 10KA RCBO	DSE201 M 2CSR375153R3104
27	16A 1P+N 300mA, 10KA RCBO	DSE201 M 2CSR375153R3164
28	20A 1P+N 300mA, 10KA RCBO	DSE201 M 2CSR375153R3204
29	25A 1P+N 300mA, 10KA RCBO	DSE201 M 2CSR375153R3254
30	32A 1P+N 300mA, 10KA RCBO	DSE201 M 2CSR375153R3324
31	40A 1P+N 300mA, 10KA RCBO	DSE201 M 2CSR375153R3404
32	50A 1P+N 300mA, 10KA RCBO	DSE201 M 2CSR375153R3504