

EQUIPMENT TYPE APPROVAL

Distribution Customer Use

We hereby confirm that below detailed Equipment is in compliance with the latest relevant regulations and standards, therefore it is **Approved** to be used in Distribution Customer Installation for five years from issuance date, where expiry date is due the Approval Holder shall apply for renewal if needed.

Application Details	
Approval ID: <i>220581</i>	Approval Holder: <i>Everest Electrical & Building Materials</i>
Approval Type: <i>Distribution Customer Use</i>	Valid Till: <i>26 Sep 2027</i>
Equipment Details	
Category: <i>LV Cables</i>	Trademark: <i>National Low Smoke</i>
Description: <i>Annexure-A</i>	Designation: <i>Annexure-A</i>
Manufacture Details	
Name: <i>M/s National Cable Industries</i>	Country of Origin: <i>United Arab Emirates</i>

Comments:

EDD Requirements Fulfilled

Signature:

Stamp:



Chief, Engineering Services Section

TERMS AND CONDITIONS

1. The Directorate reserves the right to deny or disconnect electricity supply in case of any failure to comply with any compulsory provision of the latest relevant regulations and standards enforced by the Kingdom.
2. The Directorate retains the right to publish a censored copy of the approval.
3. The Approval Holder shall observe and adhere to the latest relevant regulations and standards.
4. The Approval Holder shall observe and adhere to the latest EDD Equipment Approval guidelines and instructions which are made available at EDD Equipment Approval Web Page.
5. The Approval Holder shall ensure that an Equipment is in compliance with the latest relevant regulations and standards, and it shall not cause any harm that endangers the safety of persons, property, or environment.
6. The Approval Holder shall ensure that all provided information are accurate, relevant, correct, and complete, and that the documents submitted along with the application are true, genuine, and authentic.
7. The Approval Holder shall provide any required information, documents, and samples necessary to demonstrate Equipment conformity with the latest relevant regulations and standards.
8. The Approval Holder is responsible for retaining all relevant information and documents for five years from issuance date.
9. The Approval Holder is responsible to present the approval in full without any omissions upon request.
10. The Approval is applicable whenever an Equipment is meeting the following provisions:
 - Classified in Applicable Standards List as Distribution Customer Use Equipment.
 - Meant to be used in Distribution Customer Installation.
11. The Approval Holder for this approval shall be Supplier licensed by MOIC to place Equipment on local market.
12. The Approval Holder shall apply for the approval before placing any Equipment on local market.
13. The Approval Holder is responsible to ensure that the approved Equipment is manufactured, tested, delivered, and stored in accordance with the latest relevant regulation and standards.
14. The Installation Contractor is responsible to ensure that an approved Equipment is installed in accordance with the latest relevant regulation and standards.

ANNEXURE-A

No.	Description	Designation
1	0.6/1kV 2x1.5mm CU/MICA/XLPE/SWA/LSZH	XXXXXX
2	0.6/1kV 2x2.5mm CU/MICA/XLPE/SWA/LSZH	XXXXXX
3	0.6/1kV 2x4mm CU/MICA/XLPE/SWA/LSZH	XXXXXX
4	0.6/1kV 2x6mm CU/MICA/XLPE/SWA/LSZH	XXXXXX
5	0.6/1kV 2x10mm CU/MICA/XLPE/SWA/LSZH	XXXXXX
6	0.6/1kV 2x16mm CU/MICA/XLPE/SWA/LSZH	XXXXXX
7	0.6/1kV 2x25mm CU/MICA/XLPE/SWA/LSZH	XXXXXX
8	0.6/1kV 2x35mm CU/MICA/XLPE/SWA/LSZH	XXXXXX
9	0.6/1kV 2x35mm CU/MICA/XLPE/SWA/LSZH	XXXXXX
10	0.6/1kV 2x50mm CU/MICA/XLPE/SWA/LSZH	XXXXXX
11	0.6/1kV 2x70mm CU/MICA/XLPE/SWA/LSZH	XXXXXX
12	0.6/1kV 3x1.5mm CU/MICA/XLPE/SWA/LSZH	XXXXXX
13	0.6/1kV 3x2.5mm CU/MICA/XLPE/SWA/LSZH	XXXXXX
14	0.6/1kV 3x4mm CU/MICA/XLPE/SWA/LSZH	XXXXXX
15	0.6/1kV 3x6mm CU/MICA/XLPE/SWA/LSZH	XXXXXX
16	0.6/1kV 3x10mm CU/MICA/XLPE/SWA/LSZH	XXXXXX
17	0.6/1kV 3x16mm CU/MICA/XLPE/SWA/LSZH	XXXXXX
18	0.6/1kV 3x25mm CU/MICA/XLPE/SWA/LSZH	XXXXXX
19	0.6/1kV 3x35mm CU/MICA/XLPE/SWA/LSZH	XXXXXX
20	0.6/1kV 3x50mm CU/MICA/XLPE/SWA/LSZH	XXXXXX
21	0.6/1kV 3x70mm CU/MICA/XLPE/SWA/LSZH	XXXXXX
22	0.6/1kV 3x95mm CU/MICA/XLPE/SWA/LSZH	XXXXXX
23	0.6/1kV 3x120mm CU/MICA/XLPE/SWA/LSZH	XXXXXX
24	0.6/1kV 3x150mm CU/MICA/XLPE/SWA/LSZH	XXXXXX
25	0.6/1kV 3x185mm CU/MICA/XLPE/SWA/LSZH	XXXXXX
26	0.6/1kV 3x240mm CU/MICA/XLPE/SWA/LSZH	XXXXXX
27	0.6/1kV 3x300mm CU/MICA/XLPE/SWA/LSZH	XXXXXX
28	0.6/1kV 4x1.5mm CU/MICA/XLPE/SWA/LSZH	XXXXXX
29	0.6/1kV 4x2.5mm CU/MICA/XLPE/SWA/LSZH	XXXXXX
30	0.6/1kV 4x4mm CU/MICA/XLPE/SWA/LSZH	XXXXXX
31	0.6/1kV 4x6mm CU/MICA/XLPE/SWA/LSZH	XXXXXX
32	0.6/1kV 4x10mm CU/MICA/XLPE/SWA/LSZH	XXXXXX
33	0.6/1kV 4x16mm CU/MICA/XLPE/SWA/LSZH	XXXXXX
34	0.6/1kV 4x25mm CU/MICA/XLPE/SWA/LSZH	XXXXXX
35	0.6/1kV 4x35mm CU/MICA/XLPE/SWA/LSZH	XXXXXX
36	0.6/1kV 4x50mm CU/MICA/XLPE/SWA/LSZH	XXXXXX
37	0.6/1kV 4x70mm CU/MICA/XLPE/SWA/LSZH	XXXXXX
38	0.6/1kV 4x95mm CU/MICA/XLPE/SWA/LSZH	XXXXXX
39	0.6/1kV 4x120mm CU/MICA/XLPE/SWA/LSZH	XXXXXX
40	0.6/1kV 4x150mm CU/MICA/XLPE/SWA/LSZH	XXXXXX

ANNEXURE-A

No.	Description	Designation
41	<i>0.6/1kV 4x185mm CU/MICA/XLPE/SWA/LSZH</i>	<i>XXXXXX</i>
42	<i>0.6/1kV 4x240mm CU/MICA/XLPE/SWA/LSZH</i>	<i>XXXXXX</i>
43	<i>0.6/1kV 4x300mm CU/MICA/XLPE/SWA/LSZH</i>	<i>XXXXXX</i>