



EQUIPMENT TYPE APPROVAL

Distribution Customer Use

We hereby confirm that below detailed Equipment is in compliance with the latest relevant regulations and standards, therefore it is **Approved** to be used in Distribution Customer Installation for five years, where expiry date is due the Approval Holder shall apply for renewal if needed.

Approval Details	
Approval ID: <i>231130</i>	Approval Holder: <i>Everest Electrical W.L.L.</i>
Approval Type: <i>Distribution Customer Use</i>	Valid Till: <i>09/23/2028</i>
Equipment Details	
Category: <i>LV Switchgears</i>	Trademark: <i>LS</i>
Description: <i>Annexure-A</i>	Designation: <i>Annexure-A</i>
Manufacturer Details	
Name: <i>LSIS Co. Ltd</i>	Country of Origin: <i>South Korea</i>

Comments:

EDD Requirements Fulfilled

Signature:

09/25/2023 11:43 AM

Director, Electricity Distribution

Stamp:



To: sales@everestelectrical.com

TERMS AND CONDITIONS

1. The Directorate reserves the right to deny or disconnect electricity supply in case of any failure to comply with any compulsory provision of the latest relevant regulations and standards enforced by the Kingdom.
2. The Directorate retains the right to publish a censored copy of the approval.
3. The Approval Holder shall observe and adhere to the latest relevant regulations and standards.
4. The Approval Holder shall observe and adhere to the latest EDD Equipment Approval guidelines and instructions which are made available on EDD Equipment Approval Web Page.
5. The Approval Holder shall ensure that an Equipment is in compliance with the latest relevant regulations and standards, and it shall not cause any harm that endangers the safety of persons, property, or environment.
6. The Approval Holder shall ensure that all provided information are accurate, relevant, correct, and complete, and that the documents submitted along with the application are true, genuine, and authentic.
7. The Approval Holder shall provide any required information, documents, and samples necessary to demonstrate Equipment conformity with the latest relevant regulations and standards.
8. The Approval Holder is responsible for retaining all relevant information and documents for five years from issuance date.
9. The Approval Holder is responsible to present the approval in full without any omissions upon request.
10. The Approval is applicable whenever an Equipment is meeting the following provisions:
 - A. Classified in Applicable Standards List as Distribution Customer Use Equipment.
 - B. Meant to be used in Distribution Customer Installation.
11. The Approval Holder for this approval shall be Supplier licensed by MOIC to place Equipment on local market.
12. The Approval Holder shall apply for the approval before placing any Equipment on local market.
13. The Approval Holder is responsible to ensure that the approved Equipment is manufactured, tested, delivered, and stored in accordance with the latest relevant regulation and standards.
14. The Installation Contractor is responsible to ensure that an approved Equipment is installed in accordance with the latest relevant regulation and standards.

ANNEXURE-A

No.	Description	Designation
1	175A 4P 37kA MCCB	LS ABS204C/175
2	200A 4P 37kA MCCB	LS ABS204C/200
3	225A 4P 37kA MCCB	LS ABS204C/225
4	250A 4P 37kA MCCB	LS ABS204C/250
5	250A 3P 50kA MCCB	LS ABS403C/250
6	300A 3P 50kA MCCB	LS ABS403C/300
7	350A 3P 50kA MCCB	LS ABS403C/350
8	400A 3P 50kA MCCB	LS ABS403C/400
9	250A 4P 50kA MCCB	LS ABS404C/250
10	300A 4P 50kA MCCB	LS ABS404C/300
11	350A 4P 50kA MCCB	LS ABS404C/350
12	400A 4P 50kA MCCB	LS ABS404C/400
13	500A 3P 65kA MCCB	LS ABS803C/500
14	630A 3P 65kA MCCB	LS ABS803C/630
15	700A 3P 65kA MCCB	LS ABS803C/700
16	800A 3P 65kA MCCB	LS ABS803C/800
17	500A 4P 65kA MCCB	LS ABS804C/500
18	630A 4P 65kA MCCB	LS ABS804C/630
19	700A 4P 65kA MCCB	LS ABS804C/700
20	800A 4P 65kA MCCB	LS ABS804C/800
21	1000A 3P 65kA MCCB	LS ABS1003b/1000
22	1200A 3P 65kA MCCB	LS ABS1203b/1200
23	15A 2P 100kA MCCB	LS ABH102C/15
24	20A 2P 100kA MCCB	LS ABH102C/20
25	30A 2P 100kA MCCB	LS ABH102C/30
26	40A 2P 100kA MCCB	LS ABH102C/40
27	50A 2P 100kA MCCB	LS ABH102C/50
28	60A 2P 100kA MCCB	LS ABH102C/60
29	100A 2P 100kA MCCB	LS ABH102C/100
30	15A 3P 50kA MCCB	LS ABH103C/15
31	20A 3P 50kA MCCB	LS ABH103C/20
32	30A 3P 50kA MCCB	LS ABH103C/30
33	40A 3P 50kA MCCB	LS ABH103C/40
34	50A 3P 50kA MCCB	LS ABH103C/50
35	60A 3P 50kA MCCB	LS ABH103C/60
36	100A 3P 50kA MCCB	LS ABH103C/100
37	15A 4P 50kA MCCB	LS ABH104c/15
38	20A 4P 50kA MCCB	LS ABH104c/20
39	30A 4P 50kA MCCB	LS ABH104c/30
40	LS ABH104c/40	LS ABH104c/40