



EQUIPMENT TYPE APPROVAL

Distribution Customer Use

We hereby confirm that below detailed Equipment is in compliance with the latest relevant regulations and standards, therefore it is **Approved** to be used in Distribution Customer Installation for five years, where expiry date is due the Approval Holder shall apply for renewal if needed.

Approval Details	
Approval ID: <i>241495</i>	Approval Holder: <i>Unique Power Switchgears UPS W.L.L</i>
Approval Type: <i>Distribution Customer Use</i>	Valid Till: <i>01/30/2029</i>
Equipment Details	
Category: <i>LV Switchgears</i>	Trademark: <i>L&T</i>
Description: <i>Annexure-A</i>	Designation: <i>Annexure-A</i>
Manufacturer Details	
Name: <i>L&T Electrical & Automation</i>	Country of Origin: <i>India</i>

Comments:

EDD Requirements Fulfilled

Signature:


01/31/2024 02:27 PM
Ebrahim Khalil Ebrahim
Director, Electricity Distribution



Validation:



This approval is signed electronically, validation of the approval can be confirmed through scanning the QR Code or visiting EWA Official Website.

1. The Directorate reserves the right to deny or disconnect electricity supply in case of any failure to comply with any compulsory provision of the latest relevant regulations and standards enforced by the Kingdom.
2. The Directorate retains the right to publish a censored copy of the approval.
3. The Approval Holder is responsible for retaining all relevant information and documents for five years from issuance date.
4. The Approval Holder is responsible to present the approval in full without any omissions upon request.
5. The Approval Holder is responsible to ensure that an approved Equipment is manufactured, tested, and delivered in accordance with the latest relevant regulation and standards.
6. The Installation Contractor is responsible to ensure that an approved Equipment is installed in accordance with the latest relevant regulation and standards.
7. The Installation Contractor is responsible to validate the approval using above referenced QR Code.



ANNEXURE-A

ID	Description	Designation
241495-1	400A 3POLE AIR CIRCUIT BREAKER	U-Power Omega UW104NXD12800
241495-2	630A 3POLE AIR CIRCUIT BREAKER	U-Power Omega UW163NXD12800
241495-3	800A 3POLE AIR CIRCUIT BREAKER	U-Power Omega UW180NXD12800
241495-4	1000A 3POLE AIR CIRCUIT BREAKER	U-Power Omega UW110NXD12800
241495-5	1250A 3POLE AIR CIRCUIT BREAKER	U-Power Omega UW112NXD12800
241495-6	1600A 3POLE AIR CIRCUIT BREAKER	U-Power Omega UW116NXD12800
241495-7	400A 4POLE AIR CIRCUIT BREAKER	U-Power Omega UW104NFD12800
241495-8	630A 4POLE AIR CIRCUIT BREAKER	U-Power Omega UW163NFD12800
241495-9	800A 4POLE AIR CIRCUIT BREAKER	U-Power Omega UW180NFD12800
241495-10	1000A 4POLE AIR CIRCUIT BREAKER	U-Power Omega UW110NFD12800
241495-11	1250A 4POLE AIR CIRCUIT BREAKER	U-Power Omega UW112NFD12800
241495-12	1600A 4POLE AIR CIRCUIT BREAKER	U-Power Omega UW116NFD12800
241495-13	400A 3POLE AIR CIRCUIT BREAKER	U-Power Omega UW104NXD12900
241495-14	630A 3POLE AIR CIRCUIT BREAKER	U-Power Omega UW163NXD12900
241495-15	800A 3POLE AIR CIRCUIT BREAKER	U-Power Omega UW180NXD12900
241495-16	1000A 3POLE AIR CIRCUIT BREAKER	U-Power Omega UW110NXD12900
241495-17	1250A 3POLE AIR CIRCUIT BREAKER	U-Power Omega UW112NXD12900
241495-18	1600A 3POLE AIR CIRCUIT BREAKER	U-Power Omega UW116NXD12900
241495-19	400A 4POLE AIR CIRCUIT BREAKER	U-Power Omega UW104NFD12900
241495-20	630A 4POLE AIR CIRCUIT BREAKER	U-Power Omega UW163NFD12900
241495-21	800A 4POLE AIR CIRCUIT BREAKER	U-Power Omega UW180NFD12900
241495-22	1000A 4POLE AIR CIRCUIT BREAKER	U-Power Omega UW110NFD12900
241495-23	1250A 4POLE AIR CIRCUIT BREAKER	U-Power Omega UW112NFD12900
241495-24	1600A 4POLE AIR CIRCUIT BREAKER	U-Power Omega UW116NFD12900
241495-25	400A 3POLE AIR CIRCUIT BREAKER	U-Power Omega UW104NXD12300
241495-26	630A 3POLE AIR CIRCUIT BREAKER	U-Power Omega UW163NXD12300
241495-27	800A 3POLE AIR CIRCUIT BREAKER	U-Power Omega UW180NXD12300
241495-28	1000A 3POLE AIR CIRCUIT BREAKER	U-Power Omega UW110NXD12300
241495-29	1250A 3POLE AIR CIRCUIT BREAKER	U-Power Omega UW112NXD12300
241495-30	1600A 3POLE AIR CIRCUIT BREAKER	U-Power Omega UW116NXD12300
241495-31	400A 4POLE AIR CIRCUIT BREAKER	U-Power Omega UW104NFD12300
241495-32	630A 4POLE AIR CIRCUIT BREAKER	U-Power Omega UW163NFD12300
241495-33	800A 4POLE AIR CIRCUIT BREAKER	U-Power Omega UW180NFD12300
241495-34	1000A 4POLE AIR CIRCUIT BREAKER	U-Power Omega UW110NFD12300
241495-35	1250A 4POLE AIR CIRCUIT BREAKER	U-Power Omega UW112NFD12300
241495-36	1600A 4POLE AIR CIRCUIT BREAKER	U-Power Omega UW116NFD12300
241495-37	400A 3POLE AIR CIRCUIT BREAKER	U-Power Omega UW104NXD12400
241495-38	630A 3POLE AIR CIRCUIT BREAKER	U-Power Omega UW163NXD12400
241495-39	800A 3POLE AIR CIRCUIT BREAKER	U-Power Omega UW180NXD12400
241495-40	1000A 3POLE AIR CIRCUIT BREAKER	U-Power Omega UW110NXD12400

1. The Directorate reserves the right to deny or disconnect electricity supply in case of any failure to comply with any compulsory provision of the latest relevant regulations and standards enforced by the Kingdom.
2. The Directorate retains the right to publish a censored copy of the approval.
3. The Approval Holder is responsible for retaining all relevant information and documents for five years from issuance date.
4. The Approval Holder is responsible to present the approval in full without any omissions upon request.
5. The Approval Holder is responsible to ensure that an approved Equipment is manufactured, tested, and delivered in accordance with the latest relevant regulation and standards.
6. The MTC Contractor is responsible to ensure that an approved Equipment is installed in accordance with the latest relevant regulation and standards.
7. The MTC Contractor is responsible to validate the approval using above referenced QR Code.