



EQUIPMENT TYPE APPROVAL

Distribution Customer Use

We hereby confirm that below detailed Equipment is in compliance with the latest relevant regulations and standards, therefore it is **Approved** to be used in Distribution Customer Installation for five years, where expiry date is due the Approval Holder shall apply for renewal if needed.

Approval Details	
Approval ID: <i>241571</i>	Approval Holder: <i>Ameeri Industries Co. W.L.L.</i>
Approval Type: <i>Distribution Customer Use</i>	Valid Till: <i>02/21/2029</i>
Equipment Details	
Category: <i>LV Switchgears</i>	Trademark: <i>Himel</i>
Description: <i>Annexure-A</i>	Designation: <i>Annexure-A</i>
Manufacturer Details	
Name: <i>Delixi Electric (Wuhu) Ltd</i>	Country of Origin: <i>China</i>

Comments:

EDD Requirements Fulfilled

Signature:

02/22/2024 10:22 AM
Ebrahim Khalil Ebrahim
Director, Electricity Distribution

Validation:



This approval is signed electronically, validation of the approval can be confirmed through scanning the QR Code or visiting EWA Official Website.

1. The Directorate reserves the right to deny or disconnect electricity supply in case of any failure to comply with any compulsory provision of the latest relevant regulations and standards enforced by the Kingdom.
2. The Directorate retains the right to publish a censored copy of the approval.
3. The Approval Holder is responsible for retaining all relevant information and documents for five years from issuance date.
4. The Approval Holder is responsible to present the approval in full without any omissions upon request.
5. The Approval Holder is responsible to ensure that an approved Equipment is manufactured, tested, and delivered in accordance with the latest relevant regulation and standards.
6. The Installation Contractor is responsible to ensure that an approved Equipment is installed in accordance with the latest relevant regulation and standards.
7. The Installation Contractor is responsible to validate the approval using above referenced QR Code.



ANNEXURE-A

ID	Description	Designation
241571-1	63A 1P MCB, 10kA, B Curve	Himel HDB9H63A1B63
241571-2	6A 2P MCB, 10kA, B Curve	Himel HDB9H63A2B6
241571-3	10A 2P MCB, 10kA, B Curve	Himel HDB9H63A2B10
241571-4	16A 2P MCB, 10kA, B Curve	Himel HDB9H63A2B16
241571-5	20A 2P MCB, 10kA, B Curve	Himel HDB9H63A2B20
241571-6	25A 2P MCB, 10kA, B Curve	Himel HDB9H63A2B25
241571-7	32A 2P MCB, 10kA, B Curve	Himel HDB9H63A2B32
241571-8	40A 2P MCB, 10kA, B Curve	Himel HDB9H63A2B40
241571-9	50A 2P MCB, 10kA, B Curve	Himel HDB9H63A2B50
241571-10	63A 2P MCB, 10kA, B Curve	Himel HDB9H63A2B63
241571-11	6A 3P MCB, 10kA, B Curve	Himel HDB9H63A3B6
241571-12	10A 3P MCB, 10kA, B Curve	Himel HDB9H63A3B10
241571-13	16A 3P MCB, 10kA, B Curve	Himel HDB9H63A3B16
241571-14	20A 3P MCB, 10kA, B Curve	Himel HDB9H63A3B20
241571-15	25A 3P MCB, 10kA, B Curve	Himel HDB9H63A3B25
241571-16	32A 3P MCB, 10kA, B Curve	Himel HDB9H63A3B32
241571-17	40A 3P MCB, 10kA, B Curve	Himel HDB9H63A3B40
241571-18	50A 3P MCB, 10kA, B Curve	Himel HDB9H63A3B50
241571-19	63A 3P MCB, 10kA, B Curve	Himel HDB9H63A3B63
241571-20	6A 4P MCB, 10kA, B Curve	Himel HDB9H63A4B6
241571-21	10A 4P MCB, 10kA, B Curve	Himel HDB9H63A4B10
241571-22	16A 4P MCB, 10kA, B Curve	Himel HDB9H63A4B16
241571-23	20A 4P MCB, 10kA, B Curve	Himel HDB9H63A4B20
241571-24	25A 4P MCB, 10kA, B Curve	Himel HDB9H63A4B25
241571-25	32A 4P MCB, 10kA, B Curve	Himel HDB9H63A4B32
241571-26	40A 4P MCB, 10kA, B Curve	Himel HDB9H63A4B40
241571-27	50A 4P MCB, 10kA, B Curve	Himel HDB9H63A4B50
241571-28	63A 4P MCB, 10kA, B Curve	Himel HDB9H63A4B63
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-

1. The Directorate reserves the right to deny or disconnect electricity supply in case of any failure to comply with any compulsory provision of the latest relevant regulations and standards enforced by the Kingdom.
2. The Directorate retains the right to publish a censored copy of the approval.
3. The Approval Holder is responsible for retaining all relevant information and documents for five years from issuance date.
4. The Approval Holder is responsible to present the approval in full without any omissions upon request.
5. The Approval Holder is responsible to ensure that an approved Equipment is manufactured, tested, and delivered in accordance with the latest relevant regulation and standards.
6. The MTC Contractor is responsible to ensure that an approved Equipment is installed in accordance with the latest relevant regulation and standards.
7. The MTC Contractor is responsible to validate the approval using above referenced QR Code.